



SAIPPA



Unlocking Grid Capacity for future Independent Power Producers (IPPs)

Transmission Strategic Grid Planning

GCCA

Country Club Johannesburg, Woodmead

Ronald Marais

Transmission - Grid Planning

Presentation to SAIPPA

27 August 2015

Eskom fully supports the DOE IPP programme and has to-date taken steps to ensure the success of Transmission and Distribution network connections



Highlights contributing to the success relating to Transmission and Distribution network connections


- “ Established the **Grid Access Unit** and the **Single Buyers Office** to facilitate the connections and buy the energy respectively.
- “ Published the **Grid Connection Capacity Assessment (GCCA)** document to **guide stakeholders** to areas on the system **where network capacity is available** in relation to the renewable energy resources
- “ **Identified strategic transmission line routes** to unlock network capacity to connect future IPPs. Currently **collaborating with Department of Environmental Affairs** to initiate Strategic Environmental Impact Assessments
- “ **Committed resources to work closely with the DOE IPP Office** with the intention of aligning the IPP programme to feasible network expansion plans
- “ **Successfully enabled the network to integrate Bid Windows 1 to 3 at a cost of R2.4 Billion**
- “ **Introduced a Self Build Procedure document** that provides IPPs the option to **self build** their dedicated connection infrastructure
- “ Beyond Bid Window 3.5 and based on the IRP2010 and interest from IPPs, we have a **good indication of network requirements and cost to integrate potential IPPs up to 2024**

Since 2011, 42 projects (2124 MW) of RE IPPs were connected, ~88% (1865 MW) of which are in operation


Status of Current IPP programme

Name of programme	MW contribution	Current status
Bid Window 1 (28 projects)	1436	All 28 projects connected.
Bid Window 2 (19 projects)	1054	14 projects connected (706MW) 5 projects in execution
Bid Window 3 and 3.5 (21 projects)	1656	All budget quotations issued for 19 bid window 3 projects. 2 budget quotations due on 30 th Aug 2015 for bid window 3.5 are in progress


2142 MW of RE IPPs have been connected to the grid underpinned by a R2.4 Billion Eskom investment




All 28 projects from Bid Window 1 were connected, adding 1436 MW to the grid




14 of the 19 projects from Bid Window 2 have been completed, adding a total of 706 MW to the grid; with 5 of the projects in progress



Of the 21 Bid window 3 and 3.5 projects, 19 budget quotations have been issued




42 projects (2124 MW) of RE IPPs have been connected, between bid window 1 and 3.5, at a cost of R2.4 Billion (excluding energy cost)



Transmission Strategic Grid Planning



What have we done




- “ To **adapt to the uncertainty of future** load and generation
- “ To identify the **critical power corridors** and constraints on the transmission network
- “ Unlock and create a **flexible and robust grid** to be able to respond to the changing future needs of the country

The 2040 Transmission Network Study was undertaken to determine the development requirements of the future transmission grid to accommodate the expected load demand needs and the potential impact of future generation scenarios using the 2010 Integrated Resource Plan (IRP) as a baseline.

Why do we need Alignment

Change in Generation Spatial Footprint



Irrespective of generation scenario

Tx Strategy to increase Grid Access to meet future needs of the IRP and customers


Change in generation diversity has major impact on future Tx Grid

- “ Grid Access . Increased connection capacity needed in new areas (**delivery time > 8yr**)
- “ On Time Connection . Smaller IPP generation plant can be constructed faster (**delivery time <5yr**)
- “ Unknown locations - Multiple unspecified IPP sites require market access for best price

Change in Location - Spatial Footprint

Change in Construction 3yr - 5yr Speed of IPP plant rollout

Strategic EIAs & Servitudes can enable faster grid development




2040 Tx Study – Generation Spatial Allocation



Transmission to enable IRP requires Spatial Information




Generation Energy Resources for Electricity




However there is uncertainty in

- “ Where is the location?
- “ What is the size?
- “ What is the type?


Solar





Wind



Gas




Coal



2040 Tx Study – New Generation Allocation

Generation


Energy resources for electricity



Significant change in Generation location

Demand




Load Demand for each area for 2020 & 2040



No significant change in load location

Comparing Demand Balances for each Generation Scenario

DEMAND BALANCE PROGRESSION FOR EACH SCENARIO (Installed Generation less Maximum Demand in MW)



**Significantly
More
Transmission
Corridors and
access
required**


**Up to 2020 Demand Balance
still dominated by Centralised
generation in North**

**Beyond 2020 Demand Balance
now significantly changed by
dispersed generation in South**




Allocation of Generation Injection Points

Location of potential generation sites for all scenarios




Renewable generation intermittency will still result in large spatial variation within a single scenario.




**Base IRP
Scenario**

**Even
Spread of
Wind**




**West to
East
Pattern of
Wind**





**East to
West
Pattern of
Wind**

Comparing Demand Balances for each Generation Scenario

Current Network Transfer




Future Network Transfer




Summary of Strategic Grid Study

DEMAND BALANCE BY 2040 FOR SCENARIO A (BASE IRP)
(Allocated Generation less Maximum Demand in MW)



DEMAND BALANCE PROGRESSION FOR EACH SCENARIO
(Installed Generation less Maximum Demand in MW)




1. Municipal areas demarcated

2. Area Centroids identified


3. Adjoining Centroids linked

4. Transmission Centroid Network


GREEN WSO ABC 2040



SEA CORRIDOR ROUTES
for the 2040 NETWORK



The identified 2040 Power Corridors for SEA



Analysis of the inter-province power flows across the generation scenarios and loading conditions start to indicate where the power flows concentrate under all scenarios.

Five major corridors were identified for the future strategic development of the Tx Grid

SEA studies proposed for these routes


Mapping the Demand and Generation

Spatial Location of Load



LOAD GROWTH BY 2040 PER PROVINCE
(Maximum Demand in MW)

Incremental Load
growth in existing
load centres




Spatial location Generation




GENERATION DEVELOPMENT FOR SCENARIO A (BASE IRP)
(Maximum Demand in MW)

Dramatic
decentralisation in
Generation
location



DEMAND BALANCE BY 2040 FOR SCENARIO A (BASE IRP)
(Allocated Generation less Maximum Demand in MW)



Generation Excess
Demand Excess


Load Gx Excess /
Deficit

-	+
-	+


+
-

CSIR Renewable Zones Study under SIP 8


SEA - Wind and Solar Preferred Location



Developers - Solar Preferred Location




Developers - Wind Preferred Location



The CSIR were appointed to undertake a study to identify suitable corridors and zones for the efficient and effective rollout of wind and solar PV energy as part of NDP - SIP 8. The selection criteria included amongst others the environmental suitability of the land, the resource potential as well as exclusion areas.


Final Corridors for SEA project under SIP 10



- “ Combining all the available info and results from the supporting studies with the 2040 Network Study findings enabled the five power corridors to be further refined.
- “ DEA proposes to use SIP 10 SEA studies to undertake all the Environmental. Scoping studies which will be valid for longer period.
- “ Relatively simple process can be followed to secure the final environmental authorisation.

The SIP 10 SEA Project is currently underway and completion including government gazetting is targeted for December 2015

SGP Tx 2040 Study Corridor Overview



PHYSICAL REALITY

e.g. SKA & Mtn Range

LOAD CENTRES

Central & KZN areas

POWER POOLS

2 Concentrated areas in the North


1 large Dispersed area in the South

POWER CORRIDORS


3 from the North .
two already secured

3 from the South .
only one partially secured

Strategic Potential to Unlock more Grid Access for on-time connection of DOE programmes



Strategic Unlocking
Implementation Time




Strategic Unlocking of Renewable Access

Phased Substation and Transmission Infrastructure

The additional transmission infrastructure required to create new connection capacity can be grouped into four main phases, namely:

- Phase 1: Limited work at existing substations/projects
- Phase 2: Limited work at existing substation with limited Tx line work
- Phase 3: Existing projects or New substations with some Tx line work that requires full EIA studies and longer lead lines
- Phase 4: Existing projects or New substations with backbone Tx line work required with longest lead time



Transmission

Generation Connection Capacity Assessment (GCCA)

- “ **The Generation Connection Capacity Assessment (GCCA)**
- “ **Created in response to the call from Govt. to connect IPPs**
- “ **First one issued in 2011 for 2012 Network – GCCA-2012**
- “ **Second issued for the 2016 Network – GCCA-2016 + Rev 2**
- “ **Both based on network with approved TDP projects**
- “ **REIPPPP Bid Windows 1 to 4B have projects up to 2020**
- “ **Next rounds need info on capacity beyond 2020**

Calculation changes from the GCCA-2016



“ **Longer period into future – now 2022**

- “ Indicate all projects in TDP, approved and proposed, up to 2022
- “ Show what the future potential connection capacity could be, not just new capacity from the approved Tx projects as in GCCA-2016


“ **Local Connection Capacity is not based on N-1**

- “ In GCCA-2016 local MTS capacity based on transformer N-1
- “ Now based on total installed transformer MVA at MTS
- “ Maximum connection capacity limited to 1000MW linking to Grid Code

“ **MTS HV Busbar and Supply Areas based on N-1**


- “ Potential connection capacity at HV busbar (400kV or 275kV) based on N-1 limit to the MTS
- “ Supply Area is based on N-1 limit for the area grouping of MTS subs

Impact of TDP on connection capacity from 2016 to 2022



2016

2022



GCCA-2022 - Typical Table




Table A-9 Transmission supply area of Kimberley

Substation	Transformer Voltages	No. of Trfrs	Trfr Size (MVA)	2015 Installed Transformer (MVA)	Year of Trfr Upgrade	Upgrade Status	No. of Trfrs	Trfr Size (MVA)	2022 Installed Transformer (MVA)	REIPPP Gen Allocated (MW)	2022 LV Busbar Connection Capacity (MW)	2022 HV Busbar Connection Capacity (MW)	2022 Supply Area HV Busbar steady-state limit (MW)
Boundary	275/132	2	250	500	-	-	2	250	500	228.15	266	1422	4744
Ferrum	132/66	3	80	240	-	-	3	80	240		0	974	
	275/132	2	250	500	-	-	2	250	500	224	270		
	400/132	2	500	1000	-	-	2	500	1000	100	882		
Garona	275/132	1	125	125	-	-	1	125	125	50	74	241	
Hotazel	400/132	0	0	0	2020	Proposed	2	500	1000		980	780	
Mookodi	400/132	2	500	1000	-	-	2	500	1000	75	907	924	
Olien	275/132	2	150	300	-	-	2	150	300	239	60	403	


Improvements in GCCA-2022

- “ **Identified potential Tx projects which could unlock additional connection capacity by 2022 which are not in the TDP**
- “ **Included the 5 Tx Power Corridors in the SIP 10 SEA project which will provide a flexible and robust network that can respond to meet the needs of future IRP and IPP requirements**
- “ **Creation of an interactive spatial map in PDF format to accompany the GCCA-2022 document.**
- “ **PDF map has a number of different levels of information displayed spatially which can be toggled on & off**


GCCA-2022 - Projects for additional connection capacity




GCCA-2022 - Maps - National




GCCA-2022 - Maps – Southern Block




GCCA-2022 - Maps – Northern Block




GCCA-2022 - Maps – Central Block



GCCA-2022 - Maps – Potential Capacity not in TDP





PDF map has a number of different levels
of information displayed spatially which
can be toggled on & off

GCCA-2022 - Table interpretation

Table A-12: Transmission supply area of Namaqualand

Substation	Transformer Voltages	No. of Trfrs	Trfr Size (MVA)	2015 Installed Transformer (MVA)	Year of Trfr Upgrade	Upgrade Status	No. of Trfrs	Trfr Size (MVA)	2022 Installed Transformer (MVA)	REIPPP Gen Allocated (MW)	2022 LV Busbar Connection Capacity (MW)	2022 HV Busbar Connection Capacity(MW)	2022 Supply Area HV Busbar steady-state limit (MW)
Aggeneis	220/66	2	40	80	-	-	2	40	80	40	39	121	2348
	400/220	2	315	630	-	-	2	315	630	471.35	155		
Aries	400/22	1	40	40	-	-	1	40	40	9.65	30	116	
Gromis	220/66	2	40	80	-	-	2	40	80		78	180	
	400/220	0	0	0	2020	Proposed	1	315	315		0		
Nama	220/66	2	80	160	-	-	2	80	160		157	150	
Nieuwehoop	400/132	0	0	0	2016	Approved	1	250	250		245	750	
Oranjemond	220/66	2	80	160	-	-	2	80	160		157	100	
Paulputs	132/33	1	10	10	-	-	1	10	10	10	0	120	
	220/132	1	125	125	2019	Proposed	2	250	500	119.65	373		
Upington	400/132	1	500	500	2022	Proposed	2	500	1000	383.9	604	680	

Future Amendment of GCCA-2022



- “ GCCA-2022 was rushed out for the Expedited Bid Window programme
- “ Some minor corrections and a review of some results will result in updated values at certain substations
- “ Amended GCCA-2022 document will be issued in September
- “ However the values in the published GCCA-2022 are still valid as guideline for high level assessment
- “ Engagement with Eskom required for each IPP project

Expedited Bid Window – 2019 Risk Assessment



Province	MTS Substation Supply Area	2019 Potential Capacity in MW	BW4 Accelerated Interest in MW	Ability to Connect Risk	Comments on Risk to Connect
E Cape	Delphi	138	392.5	High Risk	Interest exceeds capacity. Large cluster of interest around 80km away. New 400/132kV substation and 400kV lines required.
E Cape	Grassridge	359	186.5	Medium Risk	Capacity available on 132kV busbar, but access to substation may be constrained.
E Cape	Jefferys Bay Area	0	166.6	High Risk	No existing capacity. New 400/132kV substation (Thyspunt) and new 400kV lines required.
E Cape	Pembroke	436	34.5	Low Risk	Capacity available on 132kV or 66kV busbar.
E Cape	Poseidon	95	415	High Risk	Interest exceeds the capacity. New 400/132kV substation (Poseidon B) closer to IPP clustering and 400kV lines required.
Free State	Everest	980	150	Low Risk	Capacity available on 132kV busbar.
Free State	Harvard	670	225	Low Risk	Capacity available on 132kV busbar.
Free State	Leander	975	150	Low Risk	Capacity available on 132kV busbar.
Free State	Mercury	284	75	Low Risk	Capacity available on 132kV busbar.

2019 Connection Capacity is estimated based on approved Tx projects

Relative Risk is based on this capacity and the level of interest in MTS Supply area

Not used to determine if IPP project can or cannot be connected

Thank you